



SIXTH FLOOR

Sources: Point2 Surveyors
Point Cloud Data (received 05/12/22)
Redhill Station

PRP
Proposed Info (received 26/06/25)
RHS-PRP-ZZ-00-DR-A-20100-Ground Floor Plan-P08.pdf
RHS-PRP-ZZ-(01-15)-DR-A-(20101-20115)-
Level (01-15) Floor Plan-P07.pdf
RHS-PRP-ZZ-ZZ-DR-A-20202-Block B North & South Elevations-P06.pdf
RHS-PRP-ZZ-ZZ-DR-A-20203-Block B East & West Elevations-P06.pdf
Redhill Station - BS9991 Updates Feb 24 - vs Jun 25 - Final.pdf

Key: Daylight Illuminance
(achieved for 50% of daylight hours)

- <50 Lux
- >50 Lux
- >100 Lux
- >150 Lux
- >200 Lux

Median Illuminance (Lux) Levels
shown for each room.

Recommended Targets:
Bedroom 100 Lux
Living Room 150 Lux
Kitchen 200 Lux

Project: Redhill Station

Title: Daylight Illuminance Distribution
Proposed Scheme Received 26/06/2025
Bloc B

Scheme Confirmed: -

Date: -

Drawn By:
MB

Scale:
1:175@A3

Date:
Jun 25

Dwg No:
P3119/000106X

Rel:
14



Appendix 4: Tabular Sunlight Results

Point 2 Surveyors Limited,
17 Slingsby Place,
London, WC2E 9AB

0207 836 5828
point2.co.uk





SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
Redhill Station Block A						
A_1/201	R1/201	LKD	20-Mar	9.7	✓	✓
	R2/201	BEDROOM	21-Mar	4.3	✓	
A_2/201	R3/201	BEDROOM	21-Mar	4.3	✓	✓
	R4/201	LKD	21-Mar	4.3	✓	
	R5/201	BEDROOM	21-Mar	0.0	✗	
A_3/201	R6/201	BEDROOM	21-Mar	1.4	✗	✓
	R7/201	BEDROOM	21-Mar	2.0	✓	
	R8/201	LKD	17-Mar	2.6	✓	
A_4/201	R9/201	BEDROOM	15-Mar	1.7	✓	✓
	R10/201	LKD	21-Mar	2.9	✓	
	R11/201	BEDROOM	21-Mar	0.0	✗	
A_5/201	R12/201	BEDROOM	21-Mar	0.0	✗	✓
	R13/201	LKD	14-Mar	3.7	✓	
	R14/201	BEDROOM	21-Mar	3.8	✓	
A_6/201	R15/201	LKD	21-Mar	3.9	✓	✓
	R16/201	BEDROOM	21-Mar	3.5	✓	
A_7/201	R17/201	LKD	21-Mar	2.0	✓	✓
	R18/201	BEDROOM	21-Mar	3.6	✓	
A_8/201	R19/201	BEDROOM	21-Mar	3.6	✓	✓
	R20/201	LKD	21-Mar	6.8	✓	
A_9/201	R21/201	LKD	21-Mar	7.4	✓	✓
	R22/201	BEDROOM	06-Mar	7.1	✓	
A_1/202	R1/202	LKD	21-Mar	9.9	✓	✓
	R2/202	BEDROOM	21-Mar	4.6	✓	
A_2/202	R3/202	BEDROOM	21-Mar	4.6	✓	✓
	R4/202	LKD	21-Mar	4.7	✓	
	R5/202	BEDROOM	21-Mar	0.0	✗	
A_3/202	R6/202	BEDROOM	21-Mar	1.6	✓	✓
	R7/202	BEDROOM	21-Mar	2.1	✓	
	R8/202	LKD	17-Mar	2.7	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
A_4/202	R9/202	BEDROOM	15-Mar	1.8	✓	✓
	R10/202	LKD	21-Mar	3.0	✓	
	R11/202	BEDROOM	21-Mar	0.0	✗	
A_5/202	R12/202	BEDROOM	21-Mar	0.0	✗	✓
	R13/202	LKD	14-Mar	4.9	✓	
	R14/202	BEDROOM	21-Mar	5.0	✓	
A_6/202	R15/202	LKD	21-Mar	5.2	✓	✓
	R16/202	BEDROOM	21-Mar	4.8	✓	
A_7/202	R17/202	LKD	21-Mar	3.1	✓	✓
	R18/202	BEDROOM	21-Mar	4.8	✓	
A_8/202	R19/202	BEDROOM	21-Mar	4.7	✓	✓
	R20/202	LKD	11-Mar	7.7	✓	
A_9/202	R21/202	LKD	03-Mar	8.0	✓	✓
	R22/202	BEDROOM	23-Feb	7.5	✓	
A_1/203	R1/203	LKD	21-Mar	10.2	✓	✓
	R2/203	BEDROOM	21-Mar	4.6	✓	
A_2/203	R3/203	BEDROOM	21-Mar	4.7	✓	✓
	R4/203	LKD	21-Mar	4.7	✓	
	R5/203	BEDROOM	21-Mar	0.0	✗	
A_3/203	R6/203	BEDROOM	21-Mar	1.7	✓	✓
	R7/203	BEDROOM	21-Mar	2.2	✓	
	R8/203	LKD	17-Mar	2.8	✓	
A_4/203	R9/203	BEDROOM	10-Mar	1.9	✓	✓
	R10/203	LKD	21-Mar	3.1	✓	
	R11/203	BEDROOM	21-Mar	0.0	✗	
A_5/203	R12/203	BEDROOM	21-Mar	0.0	✗	✓
	R13/203	LKD	14-Mar	5.3	✓	
	R14/203	BEDROOM	21-Mar	5.3	✓	
A_6/203	R15/203	LKD	21-Mar	5.6	✓	✓
	R16/203	BEDROOM	21-Mar	5.0	✓	
A_7/203	R17/203	LKD	19-Mar	3.4	✓	✓



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
	R18/203	BEDROOM	21-Mar	5.1	✓	
A_8/203	R19/203	BEDROOM	21-Mar	5.1	✓	✓
	R20/203	LKD	21-Mar	8.3	✓	
A_9/203	R21/203	LKD	24-Feb	8.3	✓	✓
	R22/203	BEDROOM	17-Feb	7.7	✓	
A_1/204	R1/204	LKD	21-Mar	10.2	✓	✓
	R2/204	BEDROOM	21-Mar	4.7	✓	
A_2/204	R3/204	BEDROOM	21-Mar	4.7	✓	✓
	R4/204	LKD	21-Mar	4.7	✓	
	R5/204	BEDROOM	21-Mar	0.0	✗	
A_3/204	R6/204	BEDROOM	21-Mar	1.8	✓	✓
	R7/204	BEDROOM	21-Mar	2.3	✓	
	R8/204	LKD	17-Mar	2.8	✓	
A_4/204	R9/204	BEDROOM	15-Mar	1.9	✓	✓
	R10/204	LKD	21-Mar	3.3	✓	
	R11/204	BEDROOM	21-Mar	0.0	✗	
A_5/204	R12/204	BEDROOM	21-Mar	0.0	✗	✓
	R13/204	LKD	14-Mar	5.6	✓	
	R14/204	BEDROOM	21-Mar	5.5	✓	
A_6/204	R15/204	LKD	21-Mar	5.8	✓	✓
	R16/204	BEDROOM	21-Mar	5.3	✓	
A_7/204	R17/204	LKD	21-Mar	3.7	✓	✓
	R18/204	BEDROOM	21-Mar	5.3	✓	
A_8/204	R19/204	BEDROOM	21-Mar	5.3	✓	✓
	R20/204	LKD	21-Mar	8.5	✓	
A_9/204	R21/204	LKD	21-Feb	8.3	✓	✓
	R22/204	BEDROOM	17-Feb	7.7	✓	
A_1/205	R1/205	LKD	21-Mar	10.2	✓	✓
	R2/205	BEDROOM	21-Mar	4.7	✓	
A_2/205	R3/205	BEDROOM	21-Mar	4.7	✓	✓
	R4/205	LKD	21-Mar	4.7	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
	R5/205	BEDROOM	21-Mar	0.0	✗	
A_3/205	R6/205	BEDROOM	21-Mar	1.8	✓	✓
	R7/205	BEDROOM	21-Mar	2.3	✓	
	R8/205	LKD	17-Mar	2.9	✓	
A_4/205	R9/205	BEDROOM	15-Mar	2.0	✓	✓
	R10/205	LKD	21-Mar	3.4	✓	
	R11/205	BEDROOM	21-Mar	0.0	✗	
A_5/205	R12/205	BEDROOM	21-Mar	0.0	✗	✓
	R13/205	LKD	14-Mar	5.6	✓	
	R14/205	BEDROOM	21-Mar	5.5	✓	
A_6/205	R15/205	LKD	21-Mar	5.8	✓	✓
	R16/205	BEDROOM	21-Mar	5.3	✓	
A_7/205	R17/205	LKD	21-Mar	3.7	✓	✓
	R18/205	BEDROOM	21-Mar	5.3	✓	
A_8/205	R19/205	BEDROOM	21-Mar	5.3	✓	✓
	R20/205	LKD	21-Mar	8.5	✓	
A_9/205	R21/205	LKD	21-Feb	8.3	✓	✓
	R22/205	BEDROOM	17-Feb	7.7	✓	
A_1/206	R1/206	LKD	21-Mar	10.2	✓	✓
	R2/206	BEDROOM	21-Mar	4.7	✓	
A_2/206	R3/206	BEDROOM	21-Mar	4.7	✓	✓
	R4/206	LKD	21-Mar	4.7	✓	
	R5/206	BEDROOM	21-Mar	0.0	✗	
A_3/206	R6/206	BEDROOM	21-Mar	1.8	✓	✓
	R7/206	BEDROOM	21-Mar	2.3	✓	
	R8/206	LKD	21-Mar	2.9	✓	
A_4/206	R9/206	BEDROOM	20-Mar	2.1	✓	✓
	R10/206	LKD	21-Mar	3.5	✓	
	R11/206	BEDROOM	21-Mar	0.0	✗	
A_5/206	R12/206	BEDROOM	21-Mar	0.0	✗	✓
	R13/206	LKD	14-Mar	5.6	✓	
	R14/206	BEDROOM	21-Mar	5.5	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
A_6/206	R15/206	LKD	21-Mar	5.8	✓	✓
	R16/206	BEDROOM	21-Mar	5.3	✓	
A_7/206	R17/206	LKD	21-Mar	3.7	✓	✓
	R18/206	BEDROOM	21-Mar	5.3	✓	
A_8/206	R19/206	BEDROOM	21-Mar	5.3	✓	✓
	R20/206	LKD	21-Mar	8.5	✓	
A_9/206	R21/206	LKD	21-Feb	8.3	✓	✓
	R22/206	BEDROOM	17-Feb	7.7	✓	
					85.6%	100.0%
Redhill Station Block B						
B_1/301	R1/301	BEDROOM	19-Mar	0.8	✗	✗
	R2/301	LKD	21-Mar	1.3	✗	
B_10/301	R25/301	BEDROOM	21-Mar	2.0	✓	✓
	R26/301	LKD	14-Mar	3.3	✓	
B_11/301	R27/301	LKD	12-Mar	4.1	✓	✓
	R28/301	BEDROOM	05-Mar	2.7	✓	
	R29/301	BEDROOM	15-Mar	2.6	✓	
B_12/301	R30/301	BEDROOM	15-Mar	2.8	✓	✓
	R31/301	BEDROOM	04-Mar	3.2	✓	
	R32/301	LKD	21-Mar	3.3	✓	
B_13/301	R33/301	LKD	21-Mar	2.7	✓	✓
	R34/301	BEDROOM	20-Mar	1.3	✗	
B_14/301	R35/301	LKD	21-Mar	2.3	✓	✓
	R36/301	BEDROOM	21-Mar	2.3	✓	
B_15/301	R37/301	LKD	21-Mar	2.4	✓	✓
	R38/301	BEDROOM	21-Mar	0.0	✗	
B_16/301	R39/301	BEDROOM	11-Mar	1.8	✓	✓
	R40/301	LKD	20-Mar	1.4	✗	
B_2/301	R3/301	BEDROOM	27-Feb	0.3	✗	✗
	R4/301	LKD	21-Mar	1.2	✗	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
B_3/301	R5/301	BEDROOM	21-Mar	0.0	✗	✗
	R6/301	BEDROOM	21-Mar	0.3	✗	
	R7/301	LKD	21-Mar	0.9	✗	
	R8/301	BEDROOM	21-Mar	0.0	✗	
B_4/301	R9/301	BEDROOM	21-Mar	0.0	✗	✓
	R10/301	BEDROOM	21-Mar	0.0	✗	
	R11/301	LKD	21-Mar	4.1	✓	
B_5/301	R12/301	LKD	15-Mar	3.4	✓	✓
	R13/301	BEDROOM	21-Mar	2.8	✓	
B_6/301	R14/301	LKD	12-Mar	3.5	✓	✓
	R15/301	BEDROOM	21-Mar	3.4	✓	
	R16/301	BEDROOM	21-Mar	2.0	✓	
B_7/301	R17/301	LKD	13-Mar	3.5	✓	✓
	R18/301	BEDROOM	21-Mar	3.4	✓	
B_8/301	R20/301	BEDROOM	21-Mar	2.4	✓	✓
	R21/301	LKD	14-Mar	3.5	✓	
B_9/301	R22/301	BEDROOM	21-Mar	3.3	✓	✓
	R23/301	BEDROOM	21-Mar	1.5	✓	
	R24/301	LKD	14-Mar	4.1	✓	
B_1/302	R1/302	BEDROOM	21-Mar	0.9	✗	✓
	R2/302	LKD	21-Mar	1.5	✓	
B_10/302	R25/302	BEDROOM	21-Mar	4.3	✓	✓
	R26/302	LKD	14-Mar	4.6	✓	
B_11/302	R27/302	LKD	21-Mar	5.7	✓	✓
	R28/302	BEDROOM	04-Mar	2.8	✓	
	R29/302	BEDROOM	04-Mar	2.7	✓	
B_12/302	R30/302	BEDROOM	15-Mar	2.8	✓	✓
	R31/302	BEDROOM	04-Mar	3.3	✓	
	R32/302	LKD	21-Mar	3.5	✓	
B_13/302	R33/302	LKD	21-Mar	2.9	✓	✓
	R34/302	BEDROOM	21-Mar	1.5	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
B_14/302	R35/302	LKD	21-Mar	2.5	✓	✓
	R36/302	BEDROOM	21-Mar	2.5	✓	
B_15/302	R37/302	LKD	19-Mar	2.5	✓	✓
	R38/302	BEDROOM	21-Mar	0.0	✗	
B_16/302	R39/302	BEDROOM	11-Mar	1.8	✓	✓
	R40/302	LKD	06-Mar	1.5	✓	
B_2/302	R3/302	BEDROOM	27-Feb	0.3	✗	✗
	R4/302	LKD	21-Mar	1.3	✗	
B_3/302	R5/302	BEDROOM	01-Mar	0.2	✗	✓
	R6/302	BEDROOM	21-Mar	0.5	✗	
	R7/302	LKD	21-Mar	1.9	✓	
	R8/302	BEDROOM	21-Mar	0.0	✗	
B_4/302	R9/302	BEDROOM	21-Mar	0.0	✗	✓
	R10/302	BEDROOM	21-Mar	0.0	✗	
	R11/302	LKD	21-Mar	5.6	✓	
B_5/302	R12/302	LKD	15-Mar	4.8	✓	✓
	R13/302	BEDROOM	21-Mar	4.7	✓	
B_6/302	R14/302	LKD	12-Mar	4.8	✓	✓
	R15/302	BEDROOM	21-Mar	4.5	✓	
	R16/302	BEDROOM	21-Mar	3.1	✓	
B_7/302	R17/302	LKD	14-Mar	4.9	✓	✓
	R18/302	BEDROOM	21-Mar	4.9	✓	
B_8/302	R20/302	BEDROOM	21-Mar	4.9	✓	✓
	R21/302	LKD	14-Mar	5.2	✓	
B_9/302	R22/302	BEDROOM	21-Mar	4.9	✓	✓
	R23/302	BEDROOM	21-Mar	4.9	✓	
	R24/302	LKD	14-Mar	5.6	✓	
B_1/303	R1/303	BEDROOM	21-Mar	1.2	✗	✓
	R2/303	LKD	21-Mar	1.7	✓	
B_10/303	R25/303	BEDROOM	21-Mar	5.2	✓	✓
	R26/303	LKD	14-Mar	5.3	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
B_11/303	R27/303	LKD	21-Mar	6.4	✓	✓
	R28/303	BEDROOM	04-Mar	2.8	✓	
	R29/303	BEDROOM	04-Mar	2.7	✓	
B_12/303	R30/303	BEDROOM	15-Mar	2.8	✓	✓
	R31/303	BEDROOM	04-Mar	3.3	✓	
	R32/303	LKD	21-Mar	3.7	✓	
B_13/303	R33/303	LKD	21-Mar	3.2	✓	✓
	R34/303	BEDROOM	21-Mar	1.8	✓	
B_14/303	R35/303	LKD	21-Mar	2.7	✓	✓
	R36/303	BEDROOM	21-Mar	2.6	✓	
B_15/303	R37/303	LKD	19-Mar	2.5	✓	✓
	R38/303	BEDROOM	21-Mar	0.0	✗	
B_16/303	R39/303	BEDROOM	11-Mar	1.8	✓	✓
	R40/303	LKD	21-Mar	1.5	✓	
B_2/303	R3/303	BEDROOM	01-Mar	0.5	✗	✗
	R4/303	LKD	21-Mar	1.4	✗	
B_3/303	R5/303	BEDROOM	01-Mar	0.3	✗	✓
	R6/303	BEDROOM	21-Mar	1.6	✓	
	R7/303	LKD	21-Mar	2.3	✓	
	R8/303	BEDROOM	21-Mar	0.0	✗	
B_4/303	R9/303	BEDROOM	21-Mar	0.0	✗	✓
	R10/303	BEDROOM	21-Mar	0.0	✗	
	R11/303	LKD	21-Mar	5.8	✓	
B_5/303	R12/303	LKD	15-Mar	5.6	✓	✓
	R13/303	BEDROOM	21-Mar	5.3	✓	
B_6/303	R14/303	LKD	12-Mar	5.1	✓	✓
	R15/303	BEDROOM	21-Mar	4.8	✓	
	R16/303	BEDROOM	21-Mar	3.4	✓	
B_7/303	R17/303	LKD	14-Mar	5.5	✓	✓
	R18/303	BEDROOM	21-Mar	5.3	✓	
B_8/303	R20/303	BEDROOM	21-Mar	5.3	✓	✓
	R21/303	LKD	14-Mar	5.6	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
B_9/303	R22/303	BEDROOM	21-Mar	5.3	✓	✓
	R23/303	BEDROOM	21-Mar	5.3	✓	
	R24/303	LKD	14-Mar	6.9	✓	
B_1/304	R1/304	BEDROOM	21-Mar	1.3	✗	✓
	R2/304	LKD	21-Mar	1.8	✓	
B_10/304	R25/304	BEDROOM	21-Mar	5.2	✓	✓
	R26/304	LKD	14-Mar	5.5	✓	
B_11/304	R27/304	LKD	21-Mar	6.4	✓	✓
	R28/304	BEDROOM	01-Mar	2.8	✓	
	R29/304	BEDROOM	04-Mar	2.7	✓	
B_12/304	R30/304	BEDROOM	15-Mar	2.8	✓	✓
	R31/304	BEDROOM	04-Mar	3.3	✓	
	R32/304	LKD	21-Mar	4.0	✓	
B_13/304	R33/304	LKD	21-Mar	3.4	✓	✓
	R34/304	BEDROOM	21-Mar	2.0	✓	
B_14/304	R35/304	LKD	21-Mar	2.8	✓	✓
	R36/304	BEDROOM	21-Mar	2.8	✓	
B_15/304	R37/304	LKD	19-Mar	2.5	✓	✓
	R38/304	BEDROOM	21-Mar	0.0	✗	
B_16/304	R39/304	BEDROOM	21-Mar	1.9	✓	✓
	R40/304	LKD	21-Mar	1.8	✓	
B_2/304	R3/304	BEDROOM	01-Mar	0.7	✗	✓
	R4/304	LKD	21-Mar	1.8	✓	
B_3/304	R5/304	BEDROOM	21-Mar	1.3	✗	✓
	R6/304	BEDROOM	21-Mar	2.2	✓	
	R7/304	LKD	21-Mar	3.1	✓	
	R8/304	BEDROOM	21-Mar	0.0	✗	
B_4/304	R9/304	BEDROOM	21-Mar	0.0	✗	✓
	R10/304	BEDROOM	21-Mar	0.0	✗	
	R11/304	LKD	21-Mar	5.8	✓	
B_5/304	R12/304	LKD	15-Mar	5.6	✓	✓



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
	R13/304	BEDROOM	21-Mar	5.3	✓	
B_6/304	R14/304	LKD	13-Mar	5.2	✓	✓
	R15/304	BEDROOM	21-Mar	4.8	✓	
	R16/304	BEDROOM	21-Mar	3.4	✓	
B_7/304	R17/304	LKD	14-Mar	5.5	✓	✓
	R18/304	BEDROOM	21-Mar	5.3	✓	
B_8/304	R20/304	BEDROOM	21-Mar	5.3	✓	✓
	R21/304	LKD	14-Mar	5.6	✓	
B_9/304	R22/304	BEDROOM	21-Mar	5.3	✓	✓
	R23/304	BEDROOM	21-Mar	5.3	✓	
	R24/304	LKD	14-Mar	6.9	✓	
B_1/305	R1/305	BEDROOM	21-Mar	1.6	✓	✓
	R2/305	LKD	21-Mar	2.1	✓	
B_10/305	R25/305	BEDROOM	21-Mar	5.2	✓	✓
	R26/305	LKD	14-Mar	5.6	✓	
B_11/305	R27/305	LKD	21-Mar	6.3	✓	✓
	R28/305	BEDROOM	01-Mar	2.8	✓	
	R29/305	BEDROOM	04-Mar	2.7	✓	
B_12/305	R30/305	BEDROOM	08-Mar	2.8	✓	✓
	R31/305	BEDROOM	04-Mar	3.3	✓	
	R32/305	LKD	21-Mar	4.1	✓	
B_13/305	R33/305	LKD	21-Mar	3.5	✓	✓
	R34/305	BEDROOM	21-Mar	2.1	✓	
B_14/305	R35/305	LKD	21-Mar	2.8	✓	✓
	R36/305	BEDROOM	21-Mar	2.8	✓	
B_15/305	R37/305	LKD	21-Mar	2.5	✓	✓
	R38/305	BEDROOM	21-Mar	0.1	✗	
B_16/305	R39/305	BEDROOM	21-Mar	2.2	✓	✓
	R40/305	LKD	21-Mar	2.0	✓	
B_2/305	R3/305	BEDROOM	21-Mar	1.3	✗	✓
	R4/305	LKD	21-Mar	3.1	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
B_3/305	R5/305	BEDROOM	21-Mar	1.8	✓	✓
	R6/305	BEDROOM	21-Mar	2.8	✓	
	R7/305	LKD	21-Mar	3.5	✓	
	R8/305	BEDROOM	21-Mar	0.0	✗	
B_4/305	R9/305	BEDROOM	21-Mar	0.0	✗	✓
	R10/305	BEDROOM	21-Mar	0.0	✗	
	R11/305	LKD	21-Mar	5.8	✓	
B_5/305	R12/305	LKD	15-Mar	5.6	✓	✓
	R13/305	BEDROOM	21-Mar	5.3	✓	
B_6/305	R14/305	LKD	13-Mar	5.2	✓	✓
	R15/305	BEDROOM	21-Mar	4.8	✓	
	R16/305	BEDROOM	21-Mar	3.4	✓	
B_7/305	R17/305	LKD	14-Mar	5.5	✓	✓
	R18/305	BEDROOM	21-Mar	5.3	✓	
B_8/305	R20/305	BEDROOM	21-Mar	5.3	✓	✓
	R21/305	LKD	14-Mar	5.6	✓	
B_9/305	R22/305	BEDROOM	21-Mar	5.3	✓	✓
	R23/305	BEDROOM	21-Mar	5.3	✓	
	R24/305	LKD	14-Mar	6.9	✓	
B_1/306	R1/306	BEDROOM	21-Mar	1.9	✓	✓
	R2/306	LKD	21-Mar	3.0	✓	
B_10/306	R25/306	BEDROOM	21-Mar	4.0	✓	✓
	R26/306	LKD	21-Mar	5.8	✓	
B_11/306	R27/306	LKD	21-Mar	6.6	✓	✓
	R28/306	BEDROOM	08-Mar	2.8	✓	
	R29/306	BEDROOM	04-Mar	2.7	✓	
B_12/306	R30/306	BEDROOM	15-Mar	2.8	✓	✓
	R31/306	BEDROOM	04-Mar	3.3	✓	
	R32/306	LKD	21-Mar	4.1	✓	
B_13/306	R33/306	LKD	21-Mar	3.5	✓	✓
	R34/306	BEDROOM	21-Mar	2.6	✓	



SUNLIGHT EXPOSURE ANALYSIS

REDHILL STATION, LONDON
PROPOSED SCHEME RECEIVED 26-06-2025

SUNLIGHT EXPOSURE

Unit	Room	Room Use	Date	Sunlight Exposure (Hours)	Room Complies?	Unit Complies?
B_14/306	R35/306	LKD	21-Mar	2.8	✓	✓
	R36/306	BEDROOM	21-Mar	2.8	✓	
B_15/306	R37/306	LKD	21-Mar	2.8	✓	✓
	R38/306	BEDROOM	21-Mar	0.3	✗	
B_16/306	R39/306	BEDROOM	21-Mar	2.4	✓	✓
	R40/306	LKD	21-Mar	2.3	✓	
B_2/306	R3/306	BEDROOM	21-Mar	2.8	✓	✓
	R4/306	LKD	21-Mar	3.5	✓	
B_3/306	R5/306	BEDROOM	21-Mar	2.8	✓	✓
	R6/306	BEDROOM	21-Mar	2.8	✓	
	R7/306	LKD	21-Mar	3.5	✓	
	R8/306	BEDROOM	21-Mar	0.0	✗	
B_4/306	R9/306	BEDROOM	21-Mar	0.0	✗	✓
	R10/306	BEDROOM	21-Mar	0.0	✗	
	R11/306	LKD	21-Mar	5.8	✓	
B_5/306	R12/306	LKD	21-Mar	5.8	✓	✓
	R13/306	BEDROOM	21-Mar	5.3	✓	
B_6/306	R14/306	LKD	21-Mar	5.3	✓	✓
	R15/306	BEDROOM	21-Mar	4.4	✓	
	R16/306	BEDROOM	21-Mar	3.4	✓	
B_7/306	R17/306	LKD	21-Mar	5.8	✓	✓
	R18/306	BEDROOM	21-Mar	5.3	✓	
B_8/306	R20/306	BEDROOM	21-Mar	4.3	✓	✓
	R21/306	LKD	21-Mar	5.8	✓	
B_9/306	R22/306	BEDROOM	21-Mar	5.3	✓	✓
	R23/306	BEDROOM	21-Mar	4.2	✓	
	R24/306	LKD	21-Mar	7.1	✓	
					80.3%	G4.8%
					82.2%	G6.7%

Point 2 Surveyors Limited,
17 Slingsby Place,
London, WC2E 9AB

0207 836 5828
point2.co.uk

